

## Corey Lafferty

---

**From:** Osborne, Aaron <AaronOsborne@miamibeachfl.gov>  
**Sent:** Thursday, November 2, 2023 1:15 PM  
**To:** Corey Lafferty  
**Subject:** RE: 3100 North Bay Road Future Crown of Road information  
**Attachments:** Project Prioritization 200401 Map.pdf

Good afternoon Corey,

The future Crown of the Road elevation adjacent to 3100 North Bay Road (Folio # 0232270080520), Miami Beach, is projected at 4.4 feet NAVD.

In 2020, the City Commission adopted a new road elevation strategy which considers sea level rise (SLR) projections and tidal flooding. Since the SLR projections vary with time, so are the proposed elevation of the roads. We are currently using the 2025 projected values (see Table 1 below), and thus the elevation of the roads at the edge of pavement for local roads like North Bay Road at the referenced address is projected to be approximately 4.2 feet NAVD ( and 4.4 feet NAVD at the crown of the road).

Table 1- Future Edge of Pavement Elevation (in feet NAVD) per Adopted Road Elevation Strategy ([PDF Road Elev 200228 reduced.pdf](#))

Project Start Date	2020	2025	2030	2035	2040
Emergency Roads	4.8	5.2	5.7	6.2	6.7
Arterial and Local Roads	3.9	4.2	4.5	4.9	5.3

Please note that the projected future road elevation is only a target and can be adjusted to ensure proper harmonization. Harmonization refers to the transition in elevations between the private property and the right of way, including the driveway and pedestrian access as well as the front and side yard transitions.

Based on the prioritization of projects (see attached map), the above subject property falls within the Lower North Bay Road A Neighborhood Improvement Project (NIP), and it is not expected to be raised within the next few years.

Feel free to contact me if you have any questions.

Best regards,

# MIAMIBEACH

**Aaron Osborne**, *Project Engineer*  
PUBLIC WORKS DEPARTMENT, Engineering Division  
1700 Convention Center Drive, Miami Beach, FL 33139  
Tel: 305-673-7080 x 26110 / Fax: 305-673-7028  
[www.miamibeachfl.gov](http://www.miamibeachfl.gov)

#### **Public Works Department Mission**

We are a multi-disciplined department comprised of Operations, Engineering, Sanitation, and Greenspace Management divisions. Together, these divisions ensure the technologically advanced design, maintenance, functionality, delivery, and cleanliness of the City's water services and resources, roadways and greenways.

We place the utmost importance in valuing our employees and ensuring all are trained to be the most reliable, knowledgeable, environmentally-conscientious and solutions-oriented professionals who provide for the City's stakeholder needs and concerns in an efficient and socially-responsible manner to foster a better, safer, and healthier community for all to live, work, and play.

**Public Works Department Vision**

To be the most proactive, innovative, and dependable network of highly knowledgeable professionals who are skilled in providing stakeholders optimal service and solutions to our community's most pressing infrastructure and environmental needs.

 ***Please do not print this e-mail unnecessarily***

---

**From:** Corey Lafferty <corey.lafferty@urbanism.com>  
**Sent:** Thursday, November 2, 2023 10:55 AM  
**To:** Osborne, Aaron <AaronOsborne@miamibeachfl.gov>  
**Subject:** 3100 North Bay Road Future Crown of Road information

You don't often get email from [corey.lafferty@urbanism.com](mailto:corey.lafferty@urbanism.com). [Learn why this is important](#)

**[ THIS MESSAGE COMES FROM AN EXTERNAL EMAIL - USE CAUTION WHEN REPLYING AND OPENING LINKS OR ATTACHMENTS ]**

Hello Giancarlo,

I am the architect for a project at 3100 North Bay Road (Folio # 0232270080520) that we are presenting to the Design Review Board process # DRB23-0973. As part of the DRB presentation, we must provide this site's Future Crown of Road elevation with written documentation from Public Work. I reviewed the Miami Beach GIS Adaptation Calculator website, and for this area, it appears that the Existing Crown of Road is at 2.6' NAVD, and the Future Crown of Road is 3.7' NAVD. I've attached a screenshot of this information below. Can you send me a letter to confirm this is the Future Crown of Road for this property?

Miami Beach Adaptation Calculator

The below information contains available data for this parcel. Note that all elevations are in feet (NAVD88)

Verify that this is the correct property:

Address: 3100 N BAY RD

Folio: 0232270080520

Existing Crown Of Road: 2.6  
(Point of the highest elevation of current road)

Future Crown Of Road: 3.7  
(Estimate of minimum elevation of future road)

Existing Edge Of Pavement: 1.6  
(Elevation of the point where the current edge of the roadway meets parcel driveway)

Future Edge Of Pavement: 3.5  
(Elevation of the point where the future edge of the roadway meets parcel driveway, based on a 10 foot road. Note that the new elevation will be gradually harmonized to the private property)


Average Ground Elevation: 3  
(Average of thousands of LIDAR ground points for the parcel)

Finished Floor Elevation: No Data  
(Top of the lowest livable floor)

Elevation Certificate Recorded: No

(An Elevation Certificate is an important tool that documents your building's elevation, is also provides proper elevation information used by the FEMA National Flood Insurance Program (NFIP) for the purpose of estimating risk premium rates necessary to provide flood insurance for new POST-FIRM Constructions that are built after 1972 or substantially improved structures in designated Special Flood Hazard Areas.)

Next Back



Best,

## COREY LAFFERTY WITH VALLE VALLE & PARTNERS

*"Serving the Development Community for 27 Years"*

770 Ponce de Leon Boulevard, Suite 308, Coral Gables, FL 33134

Tel: 305.476.9212 Fax: 305.476.9291 Cell: 786.325.7755

Email: [corey.lafferty@urbanism.com](mailto:corey.lafferty@urbanism.com) Portfolio: [www.urbanism.com](http://www.urbanism.com)



Figure ES-1

