

FERNANDO WONG

OUTDOOR LIVING DESIGN

Project: 6650 Sheffield Lane **Application No.:** DRB23-0993
Miami Beach, FL 33141

Date: 02/22/2024 **Review By:** Philip Byrnes

Discipline: LANDSCAPE

PLANNING LANDSCAPE REVIEW COMMENT

#	Comments	Response
1	Topiary pruning and hat racking is not permitted for the required lot trees. The required trees must be able to reach their mature size naturally. The desired manicured tree may be achieved in addition to the minimum number of required lot trees.	Please refer to sheet L-100_Landscape Plan which shows that we are providing and in compliance with the minimum required canopy trees for our property. We have also removed the Ficus Nitida trees from the number of trees provided to our shrub count.